

Addendum No. 2
November 28, 2022

TIA – Parking Garage Level 1 Electric Vehicle Charging Stations
Tulsa Airports Improvement Trust Project No. 70684

This addendum is hereby made a part of the project documents to the same extent as though it were originally included therein. The following changes, modifications, corrections, clarifications, additions and/or deletions as set forth herein shall apply to the above referenced proposal package and shall be made apart hereof and be subject to all of the requirements as though originally specified and/or shown. **The bidder shall acknowledge receipt of this addendum in the appropriate blank of the bid form.**

This Addendum is issued to provide the following information/clarification:

1. Contractor shall include cost for Point of Purchase Payment and Data system (PPD).

The following questions (Q) and answers (A) are provided for clarification:

Q1 What kind of Point of Purchase Payment and Data system are you looking for?

A1 The Point of Purchase Payment and Data (PPD) system requirements are as follows:

- i. The PPD must allow for Credit Card accessibility.
- ii. The PPD must be a hard wired system. Cloud hosting will not be allowed.
- iii. The terminal point for the PPD will be maintained in the TAIT Parking Operator's building server room.
- iv. The PPD will be monitored and managed by TAIT's Parking Operator.
- v. Training to operate and troubleshoot the PPD, and system must be included in the bid.

End of Addendum No. 2